

31st May 2019

HALGAN Pty Ltd
Unit 2, 187 South Creek Road
Cromer NSW 2099
Australia

SA Water House
250 Victoria Square
Adelaide South Australia 5000

GPO Box 1751
Adelaide SA 5001

Customer Technical Services
Trade Waste Branch
Telephone +61 8 7424 1336
Fax +61 8 7003 3366

ABN 69 336 525 019

Attn: Jaime Cascajares

Re: Approval for HALGAN OWHS Oil/Water Separators

Dear Jaime,

I refer to your request for authorisation of the HALGAN OWHS Oil/Water Separators.

South Australian Water Corporation approves the installation of HALGAN OWHS Oil/Water Separators (Models: OWHS 1000, OWHS 1500, OWHS 2000, OWHS 3000, OWHS 4000, OWHS 5000) as detailed in your application submitted on February 2018, for connection to SA Water's Sewerage System for a period of **5 years** from the date of this letter, subject to the following conditions. A further review will be conducted towards the end of the approval period.

Conditions of approval

1. SA Water accepts no responsibility for and does not vouch for the efficiency or performance of the product. This approval letter is not an endorsement of the product by the SA Water Corporation, and no claim shall be made through advertising, promotion or any other way.
2. The product shall be suitable for the designed application and intended environment, internally and externally for the stated life expectancy of the device.
3. Access covers for all in-ground installations of related trade waste pre-treatment infrastructure (e.g. sumps or pits) must be gas tight and water tight to prevent odour release and respectively, stormwater inflow.
4. The model shall be manufactured in accordance with the drawings submitted with the application and be supplied to the purchaser with installation instructions and procedures for maintenance and care.

5. SA Water may inspect the OWHS systems installed in customer's sites. If, in the opinion of SA Water, defects or customer complaints are significant, the authorisation of the OWHS as trade waste pre-treatment may be suspended or cancelled.
6. This approval applies to model specifications of the product as at the date of this letter. Any changes that may affect the durability or performance of the design shall be resubmitted to SA Water for evaluation.
7. Variation to the conditions of this approval may be necessary due to circumstances beyond the Corporation's control, such as changes in law. Where practicable to do so, the Corporation will give reasonable advanced notice in writing of such variation.
8. SA Water has assessed this product in principle for the use in a trade waste pre-treatment system. It has not assessed any other legislative requirements (i.e. plumbing standards).
9. This product approval may be revoked at any time if the conditions within are not adhered to.

Yours Sincerely,



Gianina Rogers

Trade Waste Technical Support Officer

Production and Treatment

SA Water

M: 0457 543 301

gianina.rogers@sawater.com.au